



Page 1 of
Date: 6/22/03
Prepared by: Jake Duhon
Signature: _____

PROJECT RIO DAILY HSE LOG

Work Area: Water Treatment Plant / Iraq

DAILY ACTIVITIES:

Construction manager and other KBR engineers on site today. Jobs going well, Khurafi workers (Indians & Iraq's) doing a good job of wearing PPE and following instructions.

Evaluated water filter tanks for entry, no equipment available yet from Khurafi. Access will be a vertical entry and require emergency equipment set up before permits can be issued. Discussed the job scope with Jim Baker, gave him a list of equipment need to begin the CSE process for the project. Khurafi already have the equipment necessary and should be getting on location asap. No entries to be conducted until all HSE requirements have been met.

X Had a discussion with Iraqi SOC workers, they confirmed the two products used in the agitators. Sodium Dichromate and Zinc Sulfate, John Monahan said he would attempt to get MSDS's off internet. Should be able to use this information for PPE requirements on CSE work. Also reviewed injection system in same area as agitators with KBR engineer, more chemicals were identified where CSE work may be needed. Not determined at this, something to watch for.

JD noted smoking material near the Halliburton diesel tanks, will cover in daily morning meetings. Khurafi to supply safety warning signs for "No Smoking" and "Do Not Enter" signs for the Halliburton HP pump areas.

SAFETY ISSUES:

No KBR CSE permits available at this time, will use KBR site safety plan documents for CSE's until approved documents become available.

Items to watch for: Climbing at heights without fall protection, hand tools, skill saw used in table saw application.

NON-SAFETY ISSUES:

5:30 am. No shooters at 3.5 this morning, moved to 60.5 and waited to 7 am for back up team to arrive. Approx 150 workers showed up a gate but no security problems were reported and group were quickly dispersed.

Reminded Jim Baker for the near miss report on the flat bed truck from 6-21-03
Khurafi interpreter not working out very well, is never available at the job locations.

JD Lewis re-assigned to DS-1 for the day, left site about 11 am



CONFIDENTIAL - SUBJECT
TO PROTECTIVE ORDER

R/LANG 04043